


# **Technical Instructions**

Document No. 155-183P25 AP 599-3 May 26, 2010

# Flowrite<sup>™</sup> AP 599 Series 4-inch Pneumatic Valve Actuator



Description	The Flowrite AP 599 Series 4-inch Pneumatic Valve Actuator is designed for use with Flowrite VF 599 Series set valves with a 3/4-inch (20 mm) stroke. This actuator is available with three spring ranges.		
Features	Three spring ranges available		
	Large diaphragm area for control accuracy		
	Easy installation and removal		
	All metal housing		
Application	These 4-inch actuators are designed to be used on Flowrite VF 599 Series valves in liquid and steam service applications.		

Product Numbers	Table 1. Ordering Information.		
	Product Number	Spring Range	Actuator Prefix Code
	599-01081	3 to 8 psi (21 to 55 kPa)	268
	599-01082	5 to 10 psi (34 to 69 kPa)	269
	599-01083	10 to 15 psi (69 to 103 kPa)	270
Ordering Information	To order a complete valve plus actuator assembly from the factory, combine the actuator prefix code with the suffix of the valve product number. See <i>TB</i> 249 Flowrite Valve and Actuator Assembly Selection Technical Bulletin (155-304P25) for selection procedures.		

To order an actuator only, use the product number in Table 1.

### **Warning/Caution Notations**

WARNING:	Personal injury/loss of life may occur if you do not perform a procedure as specified.
CAUTION:	Equipment damage may occur if you do not perform a procedure as specified.

Specifications	Effective diaphragm area Diaphragm material Nominal spring range	11-inch <sup>2</sup> (71 cm <sup>2</sup> ) Silicone 3 to 8 psi (21 to 55 kPa)
		5 to 10 psi (34 to 69 kPa) 10 to 15 psi (69 to 103 kPa)
	Nominal stroke	3/4-inch (20 mm)
	Maximum diaphragm pressure Air Connection	35 psi (241 kPa) 1/8-inch NPT
	Ambient operating and storage temperature	0 to 225°F (-18 to 107°C)
	Mounting location Dimensions	NEMA 1 (interior only) 5-3/4 inch H $\times$ 5-1/2 inch diameter
	Weight	(146 mm H × 137 mm diameter) 2.5 lb (1.1 kg)
Service Kit	Diaphragm replacement kit (Package of one)	599-01093

## Operating

The control air signal upon the diaphragm causes the valve to modulate whenever the air pressure is within the spring range of the actuator. The actuator spring provides the necessary force to hold the stem in the stem up position.




Figure 1. Actuator Operation.

#### Service

Complete instructions are included in the diaphragm replacement kit.


WARNING:

the actuator top.

**Diaphragm Replacement** 



#### Mounting and Installation



This product contains a spring under high compression. Make sure the valve stem is held securely in the stem retainer before removing

Figure 2. Acceptable Mounting Positions.


Allow eight inches (200 mm) headroom and six inches (150 mm) on either side of the actuator.


For best performance, install the actuator vertically above the valve. The actuator can be installed in any position between vertical and horizontal. Siemens Industry, Inc. does not recommend installing the actuator below horizontal or up side down. See Figure 2 for allowable mounting positions.

Complete instructions for field mounting the actuator are included with the actuator.

The "0" marking on the actuator yoke indicates stem up position. The "1" mark indicates stem down position. See Figure 1.

#### **Actuator Details**





ltem	Description	Quantity	Material
1	Actuator top screw	6	Plated steel
2	Actuator top	1	Aluminum
3	Diaphragm	1	Silicone
4	Piston cup	1	Aluminum
5	Spring - 3 to 8 and 5 to 10 psi - 10 to 15 psi	1	Music wire Chrome silicone steel
6	Stem retainer	1	Plated steel
7	Actuator yoke	1	Aluminum
8	Actuator retainer screw	2	Plated steel
9	Actuator retainer nut	2	Plated steel
Diaphragm replacement kit			Item 3 599-01093

Information in this publication is based on current specifications. The company reserves the right to make changes in specifications and models as design improvements are introduced. Flowrite is a registered trademark of Siemens Industry, Inc. Product or company names mentioned herein may be the trademarks of their respective owners. © 2010 Siemens Industry, Inc.

Siemens Industry, Inc. Building Technologies Division 1000 Deerfield Parkway Buffalo Grove, IL 60089 + 1 847-215-1000 Your feedback is important to us. If you have comments about this document, please send them to <u>sbt\_technical.editor.us.sbt@siemens.com</u>