

Test report MTBF (based on SN29500)

We **Siemens Schweiz AG**
Wir **Smart Infrastructure Global Headquarters**
Theilerstrasse 1a
CH-6300 Zug

declare under our sole responsibility that the products
erklären in alleiniger Verantwortung, dass die Produkte

Product(s) **FMS**
Produkt(e)

AQR2531ANW	AQR2546NG
AQR2532NNW	AQR2570NF
AQR2530NNW	AQR2570NH
AQR2535NNW	AQR2570NG
AQR2540NF	AQR2576NF
AQR2540NH	AQR2576NH
AQR2540NG	AQR2535NNWQ
AQR2547NF	AQR2576NG
AQR2546NF	AQR2534ANW
AQR2548NF	AQR2570NJ
AQR2546NH	AQR2576NJ

to which this report relates, comply to the requirements of the Siemens Common HW standard and passed the below listed internal calculation successfully.

Target values are: MTBF > 1752000 hours (equal to 200 years, and failure rate $I < 0.5\%$ /year, over 10 years in use) PS: MTBF mean operating time between failures.

Reliability prediction standard

SN 29500

CH-6300 Zug, 18.04.2022

Unterzeichnet für und im Namen von: / Signed for and on behalf of:

Siemens Schweiz AG

Nitz
Thomas
i.V.
Thomas Nitz
Product Management, Portfolio & Innovation Head

Digitally signed
by Nitz Thomas
Date: 2022.05.19
20:05:18 +02'00'

Huang
Jian

Digitally signed by Huang Jian
DN: cn=Huang Jian, o=Siemens,
email=joseff.huang@siemens.com
Date: 2022.05.12 13:01:43 +08'00'

i.V.
Huang Jian
Head of R&D SI BP MA BSCE R&D